

16(d) Bronze Asbestos Packed Water Level Gauge Flanged Ends, Right Hand Operated

Description

- NETA Bronze Asbestos Packed Water Level Gauge
- Flanged BS-10 Table 'F' Ends
- Right Hand Operated

Test Pressure

Max. BOP : 150 PSIG

Max. Working Temperature : 220°C

Test Pressure : 300 PSIG Hyd.

Certification

IBR Test Certificate in FORM III-C duly signed by the Director of Boilers, Punjab is provided.

Application : Steam, Water

HSN : 84818020



Materials

| PNo. | Part | Nos. | Material | Standard |
|------|-----------------|------|--------------------|---------------------|
| 1 | Top Cover | 1 | Bronze | IBR 282[a][iv] Gr.B |
| 2 | Gasket | 2 | C.A.F. | IS:2712 |
| 3 | Nut | 2 | Bronze | IBR 282[a][iv] Gr.B |
| 4 | Top Arm | 1 | Bronze | IBR 282[a][iv] Gr.B |
| 5 | Packing | - | Graphited Asbestos | - |
| 6 | Gland | 2 | Bronze | IBR 282[a][iv] Gr.B |
| 7 | Gland Nut | 2 | Bronze | IBR 282[a][iv] Gr.B |
| 8 | Glass Tube | 1 | Glass | - |
| 9 | Lower Arm | 1 | Bronze | IBR 282[a][iv] Gr.B |
| 10 | Drain Cock Body | 1 | Bronze | IBR 282[a][iv] Gr.B |
| 11 | Plug Nut | 3 | Bronze | IBR 282[a][iv] Gr.B |
| 12 | Plug | 3 | Bronze | IBR 282[a][iv] Gr.B |
| 13 | Adjusting Nut | 3 | Bronze | IBR 282[a][iv] Gr.B |
| 14 | Drain Nut | 1 | Bronze | IBR 282[a][iv] Gr.B |
| 15 | Nozzle | 1 | Bronze | IBR 282[a][iv] Gr.B |

Dimensions

| Nominal Size (Inches) | Nominal Size (mm) | L ±1.5 | D ±1.0 | T (Min) |
|-----------------------|-------------------|--------|--------|---------|
| 1/2 | 15 | 70 | 95.3 | 9.5 |
| 5/8 | 16 | 95 | 101.6 | 9.5 |
| 3/4 | 20 | 95 | 101.6 | 9.5 |

